

SECTION 104400 - FIRE- PROTECTION SPECIALTIES

PART 1 - GENERAL

1.1 SECTION REQUIREMENTS

- A. Submittals: Product Data.
- B. Fire Extinguishers: NFPA 10, listed and labeled for the type, rating, and classification of extinguisher.

PART 2 - PRODUCTS

2.1 FIRE EXTINGUISHERS AND CABINETS

- A. Fire Protection Cabinets: Aluminum, semi-recessed cabinets for fire extinguisher.
 - 1. J.L. Industries Inc., Commerce, California (323)-726-9070, “Academy” 1027W10, or equal.
 - 2. Trim Style: 2 ½” Aluminum rolled trim, clear anodized.
 - 3. Door Style: Contemporary tempered vision glass with Safe-t-lock.
 - 4. Accessories: Mounting brackets; Identification lettering; 10 pound, U.L. rated 4-A, chemical filled fire extinguisher rated for Class A, B or C fires.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install cabinets and brackets at heights indicated or, if not indicated, at heights to comply with applicable regulations of authorities having jurisdiction.

END OF SECTION 104400