

SECTION 230548 - SEISMIC RESTRAINT

PART 1 - GENERAL

1.1 RELATED DOCUMENTS:

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Specification Sections, apply to this Section.

1.2 WORK INCLUDED:

- A. All equipment, piping, and ductwork shall be adequately restrained to resist seismic forces. Restraint of rigidly mounted ductwork and piping may conform to "Guidelines for Seismic Restraints of Mechanical Systems and Plumbing Piping Systems", SMACNA/PPIC, latest edition, and calculations need not be submitted for restraint systems conforming to these guidelines.

PART 2 - PRODUCTS

2.1 MATERIALS:

- A. Products shall be made expressly for the purpose of seismic restraint, and shall be manufactured by Mason or Amber/Booth or equal.

PART 3 - EXECUTION

3.1 WORK:

- A. All work is to be done in conformance with the aforementioned Codes and References.
- B. Provide floor-mounted "Quakemaster" or equal seismic restraint on water heater.

END OF SECTION 230548